

Supplement to Certificate of Compliance

Certificate: 2494369 Master Contract: 254100

The products listed, including the latest revision described below, are eligible to be marked in accordance with the referenced Certificate.

Product Certification History

| Project | Date | Description |
|----------|-------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| 70032715 | Nov 2, 2015 | Transformer enclosure (DK4141 gasket) with CSA Type 3R rating to CSA C22.2 No. 94. Review UL gasket test data. A new quote will be provided if additional test is required. Rain test for CSA Type 3R will be done on a representive sample at CSA. The sample shall be made with the max distances of two adjacent sealing bolts along the gasket as shown in engineering drawing. |
| 2494369 | Jun 8, 2012 | Original Safety Certification for Dry-Type Distribution Transformer up to 500kVA. |

DQD 507 Rev. 2012-05-22 Page: 1